

CHONGQING CUMMINS ENGINE COMPANY Ltd.

Basic Engine Model:
KTA38-P1490

Curve Number:

Page

Engine Critical Parts List:

Date:

No.

ENGINE PERFORMANCE CURVE

www.cumminspowerunits.com

Displacement: 37.8 litre (2300 in³) Bore: 159 mm (6.25 in.) Stroke: 159 mm (6.25 in.)

No. of Cylinders: 12 Aspiration: Turbocharged and Aftercooled

Engine Speed	Standby Power		Prime Power		Continuous Power	
RPM	kWm	ВНР	kWm	ВНР	kWm	ВНР
1500						
1800	1112	1490	1007	1350	776	1040


Engine Performance Data @ 1500 RPM

Not Available at 1500 RPM

Not Available at 1500 RPM

Engine Performance Data @ 1800 RPM

OUTPUT POWER			FUEL CONSUMPTION			
%	kWm	ВНР	kg/ kWm⋅h	lb/ BHP∙h	litre/ hour	U.S. Gal/ hour
STANDBY POWER						
100	1112	1490	0.207	0.341	271	71.5
PRIME POWER						
100	1007	1350	0.207	0.340	245	64.6
75	755	1012	0.214	0.351	190	50.1
50	504	675	0.229	0.379	136	36.0
25	252	338	0.273	0.452	81	21.5
CONTINUOUS POWER						
100	776	1040	0.212	0.348	193	51.0



CONVERSIONS:

(Litres = U.S. Gal x 3.785)

 $(kWm = BHP \times 0.746)$

 $(U.S. Gal = Litres \times 0.2642)$

(BHP = Engine kWm x 1.34)

Data shown above represent gross engine performance capabilities obtained and corrected in accordance with ISO-3046 conditions of 100 kPa (29.53 in Hg) barometric pressure [110 m (361 ft) altitude], 25 °C (77 °F) air inlet temperature, and relative humidity of 30% with No. 2 dieel or a fuel corresponding to ASTM D2. See reverse side for application rating guidelines.

The fuel consumption data is based on No. 2 diesel fuel weight at 0.85 kg/litre (7.1 lbs/U.S. gal).

Power output curves are based on the engine operating with fuel system, water pump and lubricating oil pump; not included are battery charging alternator, fan, optional equipment and driven components.

TECHNICAL DATA DEPT. CERTIFIED WITHIN 5% CHIEF ENGINEER

POWER RATING APPLICATION GUIDELINES FOR GENERATOR DRIVE ENGINES

These guidelines have been formulated to ensure proper application of generator drive engines in A.C. generator set installations. Generator drive engines are not designed for and shall not be used in variable speed D.C. generator set applications.

STANDBY POWER RATING is applicable for supplying emergency power for the duration of the utility power outage. No overload capability is available for this rating. Under no condition is an engine allowed to operate in parallel with the public utility at the Standby Power rating.

This rating should be applied where reliable utility power is available. A standby rated engine should be sized for a maximum of an 80% average load factor and 200 hours of operation per year. This includes less than 25 hours per year at the Standby Power rating. Standby ratings should never be applied except in true emergency power outages. Negotiated power outages contracted with a utility company are not considered an emergency.

CONTINUOUS POWER RATING is applicable for supplying utility power at a constant 100% load for an unlimited number of hours per year. No overload capability is available for this rating.

PRIME POWER RATING is applicable for supplying electric power in lieu of commercially purchased power. Prime Power applications must be in the form of one of the following two categories:

UNLIMITED TIME RUNNING PRIME POWER

Prime Power is available for an unlimited number of hours per year in a variable load application. Variable load should not exceed a 70% average of the Prime Power rating during any operating period of 250 hours.

The total operating time at 100% Prime Power shall not exceed 500 hours per year.

A 10% overload capability is available for a period of 1 hour within a 12 hour period of operation. Total operating time at the 10% overload power shall not exceed 25 hours per year.

LIMITED TIME RUNNING PRIME POWER

Prime Power is available for a limited number of hours in a non-variable load application. It is intended for use in situations where power outages are contracted, such as in utility power curtailment. Engines may be operated in parallel to the public utility up to 750 hours per year at power levels never to exceed the Prime Power rating. The customer should be aware, however, that the life of any engine will be reduced by this constant high load operation. Any operation exceeding 750 hours per year at the Prime Power rating should use the Continuous Power rating.

Reference Standards:

BS-5514 and DIN-6271 standards are based on ISO-3046.

Operation At Elevated Temperature And Altitude:

The engine may be operated at:

1800 RPM up to 5,000 ft. (1525 m) and 104 $^{\circ}$ F (40 $^{\circ}$ C) without power deration.

For sustained operation above these conditions, derate by 4% per 1,000 ft (300 m), and 1% per 10° F (2% per 11° C).

Chongqing Cummins Engine Company Ltd.

Engine Data Sheet

ENGINE MODEL: KTA38-P1490 CONFIGURATION NUMBER: D233031DX02 DATE: DEFFORMANCE CURVE:

INSTALLATION DIAGRAM

<u>CPL NUMBER</u>Engine Critical Parts List

Fan to Flywheel :
 Heat Exchanger Cooled :

Heat Exchanger Cooled :		
GENERAL ENGINE DATA		
Type		e; 12-Cylinder Diesel
Aspiration	Turbocharged a	and Aftercooled
Bore x Stroke	6.25 x 6.25 (159	x 159)
Displacement—in ³ (liter)	2300 (37.8)	
Compression Ratio	13.9 : 1	
Dn. Wainht		
Dry Weight	0400	(4200)
Fan to Flywheel Engine	9482	(4300)
Heat Exchanger Cooled Engine	9923	(4500)
Wet Weight	10000	(4500)
Fan to Flywheel Engine	10002	(4536)
Heat Exchanger Cooled Engine— Ib (kg)	10602	(4808)
Moment of Inertia of Rotating Components		
• with FW 6001 Flywheel	248	(10.4)
• with FW 6011 Flywheel — lb _m • ft² (kg • m²)	493	(20.8)
Center of Gravity from Rear Face of Flywheel Housing (FH 6024)	38.6	(980)
Center of Gravity above Crankshaft Centerline	11.0	(279)
Maximum Static Loading at Rear Main Bearing	2000	(908)
Maximum Static Loading at Near Main Dealing	2000	(906)
ENGINE MOUNTING		
Maximum Bending Moment at Rear Face of Block — lb • ft (N • m)	4500	(6100)
EVILATICE CVCTEM		
EXHAUST SYSTEM	-	(7.0)
Maximum Back Pressure— in Hg (mm Hg)	3	(76)
AIR INDUCTION SYSTEM		
Maximum Intake Air Restriction		
• with Dirty Filter Element	25	(635)
• with Normal Duty Air Cleaner and Clean Filter Element		
	10	(254)
• with Heavy Duty Air Cleaner and Clean Filter Element	15	(381)
COOLING SYSTEM		
Coolant Capacity — Engine Only— US gal (liter)	32.7	(124)
— with HX 6076 Heat Exchanger— US gal (liter)	52.7	(199)
Will 177 007 0 Fleat Exolating Financian in the second financial in the second	02.7	(100)
Maximum Coolant Friction Head External to Engine — 1800 rpm — psi (kPa)	10	(69)
— 1500 rpm — psi (kPa)		N/A
Maximum Static Head of Coolant Above Engine Crank Centerline	60	(18.3)
Standard Thermostat (Modulating) Range	180 - 200	(82 - 93)
Minimum Pressure Cap — psi (kPa)	10	(69)
Maximum Top Tank Temperature for Standby / Prime Power	220 / 212	(104 / 100)
Minimum Raw Water Flow @ 90°F to HX 6076 Heat Exchanger	108	(409)
Maximum Raw Water Inlet Pressure at HX 6076 Heat Exchanger	50	, ,
waximum haw water inlet riessure at nx 6076 heat exchanger	50	(345)
LUBRICATION SYSTEM		
Oil Pressure @ Idle Speed — psi (kPa)	20	(138)
@ Governed Speed — psi (kPa)	45 - 65	(310 - 448)
Maximum Oil Temperature	250	(121)
Oil Capacity with OP 6023 Oil Pan : High - Low	30 - 23	(121)
Total System Capacity (Including Bypass Filter)	35.7	(135)
Angularity of OP 6023 Oil Pan — Front Down	33.7	30°
— Front Up		30°
— Side to Side		30°

FUEL SYSTEM

Type Injection System	Direct Injection	Cummins PT
Maximum Restriction at PT Fuel Injection Pump — with Clean Fuel Filter	4.0	(102)
— with Dirty Fuel Filter in Hg (mm Hg)	8.0	(203)
Maximum Allowable Head on Injector Return Line (Consisting of Friction Head and Static Head)	6.5	(165)
Maximum Fuel Flow to Injection Pump — US gph (liter / hr)	134	(507)
ELECTRICAL SYSTEM		
Cranking Motor (Heavy Duty, Positive Engagement)	24	
Battery Charging System, Negative Ground — ampere	35	
Maximum Allowable Resistance of Cranking Circuit — ohm	0.002	
Minimum Recommended Battery Capacity		
• Cold Soak @ 50 °F (10 °C) and Above	1200	
• Cold Soak @ 32 °F to 50 °F (0 °C to 10 °C)	1280	
• Cold Soak @ 0 °F to 32 °F (-18 °C to 0 °C)	1800	

PERFORMANCE DATA

All data is based on:

- Engine operating with fuel system, water pump, lubricating oil pump, air cleaner and exhaust silencer; not included are battery charging alternator, fan, and optional driven components.
- Engine operating with fuel corresponding to grade No. 2-D per ASTM D975.
- ISO 3046, Part 1, Standard Reference Conditions of:

Barometric pressure : 100 kPa (29.53 in Hg) Air Temperature : 25°C (77°F)
Altitude : 110 m (361 ft) Relative Humidity : 30%

STANDBY 60 hz 50 hz

Governed Engine Speedrpm
Engine Idle Speed — rpm
Gross Engine Power Output BHP (kW _m)
Brake Mean Effective Pressurepsi (kPa)
Piston Speed—ft / min (m / s)
Friction Horsepower — HP (kW _m)
Engine Water Flow at Stated Friction Head External to Engine:
• 4 psi Friction Head — US gpm (liter / s)
Maximum Friction Head — US gpm (liter / s)

60 HZ	50 HZ	60 HZ	50 HZ
1800 725 - 775 1490 (1112) 285 (1965) 1875 (9.5) 170 (127) 390 (24.6) 340 (21.4)	Not Applicable for	1800 725 - 775 1350 (1007) 258 (1779) 1875 (9.5) 170 (127) 390 (24.6) 340 (21.4)	Not
3040 (1435) 975 (524) 8405 (3967) 26.4:1 9275 (163) 38740 (681) 43365 (762)	Operation	2880 (1359) 930 (499) 7715 (3641) 27.7:1 8420 (148) 35100 (617) 39510 (694)	

N.A. - Data is Not Available

N/A - Not Applicable to this Engine

TBD - To Be Determined

ENGINE MODEL: KTA38-P1490

PRIME POWER

DATA SHEET : DATE : CURVE NO. :

CHONGQING CUMMINS ENGINE COMPANY Ltd. China Chongqing 400031